

Gas Information Sheet No. 03

Fire resistant boards

According to the suppliers, the following materials comply with the requirements of AS 5601 - Gas Installations, Appendix C. Other materials may also comply, check with the supplier.

Proprietary name of material	Minimum thickness required	Supplier
Bellis Board Firemaster 550* Supalux Promina Promatect H	9 mm 10 mm 9 mm 9 mm 12 mm	Bellis Australia Pty Ltd. 2/11 Havelock Road Bayswater (03) 9720 5100
Bellis Board (Available in cut sheets) (1200 X 600 mm)	9mm	Bradflo 7 Rushdale Street Knoxfield (03) 9764 9656
Firemaster 550* (*Not acceptable for use where it would support an appliance)	10 mm	Thermal Ceramics Unit 3/4 111-113 William Angliss Drive North Laverton (03) 9360 0355
Supalux	9 mm	Trafalgar Building Products 10 Brunsdon Street Bayswater (03) 9729 2141 OR Thermal Electric Elements Factory 4/257 Governor Rd Braeside (03) 9580 6222
Promina Promatect H	12 mm 12 mm	Promat Australia 3/273 Williamstown Road Port Melbourne (03) 9645 3866 or 1800 302 020
Powerscape Health (Vertical surfaces only)	13 mm	USG Powerscape PO Box 7450 St Kilda Rd. Melbourne 3205 1800 226 215

If further information is required, please phone the Gas Safety Technical Information Line on 1800 652 563.



Ken Gardner
Director of Energy Safety